


ANSI / WSC PST 2000 - 2005

Pressurized Water Storage Tank

**American National Standard /
Water Systems Council
Standard**



**American National Standard /
Water Systems Council Standard**

Pressurized Water Storage Tank


Standard Developer
NSF International

Approved June 10, 2005

American National Standards Institute

June 10, 2005

Designated as an ANSI Standard



Sponsor
NSF International

Prepared by
**The NSF Canvass Committee on
Pressurized Storage Tanks**

Recommended for Adoption by
**The NSF Canvass Committee on
Pressurized Storage Tanks**

Adopted by
**The WSC Board of Directors
November 2000**

Published September 2005

Published by

Water Systems Council
1101 30th Street, N.W.
Suite 500
Washington, DC 20007

Printed in the United States of America.

Contents

| | |
|---|------------|
| Foreword | v |
| Collaborating organizations | vii |
| 1. Scope | 1 |
| 2. Reference documents | 1 |
| 3. Definitions and symbols | 2 |
| 3.1 Definitions | 2 |
| 3.2 Symbols | 3 |
| 4. Materials | 3 |
| 4.1 General | 3 |
| 4.2 Types of materials | 4 |
| 5. Design acceptance criteria | 4 |
| 5.1 General requirements | 4 |
| 5.2 Prototype testing | 5 |
| 6. Minimum construction performance criteria | 7 |
| 6.1 Design method by calculation for steel tanks | 7 |
| 6.2 Design method by hydrostatic test | 8 |
| 7. Production testing | 8 |
| 8. Markings | 8 |
| 9. Instructions | 9 |
| Annex A | A1 |
| A.1 Listings | A1 |
| A.2 Enforcement | A1 |
| Annex B | B1 |

Foreword¹

It is the purpose of this standard to prescribe minimum performance and construction requirements for pressurized storage tanks for service in water well systems with a maximum factory pre-charge pressure of 40 psig (280 kPa), to be operated in ambient air temperatures up to 120°F (49°C), with maximum working pressures not less than 75 psig (520 kPa) and not greater than 150 psig (1000 kPa) and tank volumes not exceeding 120 gallons (450 L).

Most private water systems are powered by an electric motor and incorporate a closed pressure tank. The three essential components of such a system are pump, tank and control. The functions of a water pressure storage tank are threefold: (1) to protect and prolong the life of the pump by preventing rapid cycling of the pump motor (most motor manufacturers recommend pump cycle rates of under 300 for each 24-hour period and not more than 15 starts per hour for up to 3/4 hp, and not more than 7-1/2 starts per hour for greater than 3/4 hp motors); (2) to provide water under pressure for delivery between cycles; and (3) to provide additional water storage under pressure to assist the pump in meeting the total demands of a system if the pump or well is incapable of supplying the required capacity.

ANSI/WSC PST-2000 Pressurized Water Storage Tank Standard can be used by regulatory agencies when developing codes for pressurized storage tanks

In 1999, a group of WSC members comprised of leading U.S. manufacturers of pressurized water storage tanks for water wells met to define and promote, through voluntary written standards, minimum

¹ The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Foreword may contain material that has not been subjected to public review of a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

performance and construction requirements for pressurized water storage tanks for service in water well systems. The Water Systems Council Board of Directors approved this voluntary standard in November 2000.

This American National Standard was developed in 2005 by the NSF Canvass Committee on Pressurized Storage Tanks using the consensus process described by the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. Comments should be sent to Secretariat, NSF Canvass Committee on Pressurized Storage Tanks, c/o NSF International, Standards Department, PO Box 130140, Ann Arbor, Michigan 48113-0140, USA.

The Office of the Water Systems Council can be contacted at 202-625-4387 or at www.watersystemscouncil.org.

Collaborating Organizations

Water Systems Council

The Water Systems Council (WSC) is a National non-profit organization, dedicated to promote the wider use of wells as modern and affordable safe drinking water systems and to protect ground water resources. WSC members include major manufacturers of the integral components of wells and other small drinking water systems, leading distributors of those components, and other drinking water professionals.

Founded in 1932, WSC is dedicated to protect the public health and ground water resources through product excellence and informational services. WSC represents the manufacturing and engineering skill and water well knowledge of the nation's water tank, accessory and well supply manufacturers. WSC endeavors to work closely with industry and public health groups.

WSC is the only national organization solely focused on individual water wells and other private well-based water systems.

NSF International

NSF International, The Public Health and Safety Company™, a not-for-profit, non-governmental organization, is the world leader in standards development, product certification, education, and risk management for public health and safety. For 60 years, NSF has been committed to public health, safety, and protection of the environment. While focusing on food, water, indoor air, and the environment, NSF develops national standards, provides learning opportunities through its Center for Public Health Education, and provides third-party conformity assessment services while representing the interests of all stakeholders. The primary stakeholder groups include industry, the regulatory community and the public at large.

NSF is widely recognized for its scientific and technical expertise in the health and environmental sciences. Its professional staff includes engineers, chemists, toxicologists, and environmental health professionals with broad experience both in public and private organizations.

NSF has earned the Collaborating Center designations by the World Health Organization (WHO) for Food and Water Safety and Indoor Environment.

Serving manufacturers operating in 80 countries, NSF was founded in 1944 and is headquartered in Ann Arbor, MI USA. The NSF Mark is recognized for its value in international trade around the world and is respected by regulatory agencies at the local, state and federal levels.

ANSI / WSC Standard – Standard Pressurized Water Storage Tanks (PST-2000)

1. SCOPE

This standard prescribes minimum performance and construction requirements for pressurized storage tanks for service in water well systems with a maximum factory pre-charge pressure of 40 psig (280 kPa), to be operated in ambient air temperatures up to 120°F (49°F), with maximum working pressures not less than 75 psig (520 kPa) and not greater than 150 psig (1000 kPa) and tank volumes not exceeding 120 gallons (450 L).

2. REFERENCE DOCUMENTS

The following documents contain provisions that, through reference, constitute provisions of this ANSI/WSC Standard. All documents are subject to revision, and parties are encouraged to investigate the recent editions of the documents indicated below.

ASTM A1008/A1008M *Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy and High-Strength Low-Alloy with Improved Formability*¹

ASTM A1011/A1011M *Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy and High-Strength Low-Alloy with Improved Formability*¹

Code of Federal Regulations, Title 49, Part 173.306(g), *Transportation*²

NSF/ANSI Standard 61 – Drinking Water System Components – Health Effects³

¹ ASTM International, 100 Barr Harbor Dr., West Conshohocken, PA 19428

² National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, VA

³ NSF International, P.O. Box 130140, Ann Arbor, Mi 48113-0140

3. DEFINITIONS AND SYMBOLS

3.1 DEFINITIONS

- 3.1.1 **Circumferential:** Perpendicular to the centerline axis of the tank.
- 3.1.2 **Composite materials:** Composite materials are material structures that include, but are not limited to, fiber, laminates and particulate composites.
- 3.1.3 **Concave:** The curved portion of the head that is outward in respect to the inside of the tank.
- 3.1.4 **Dome:** The curved portion of the head.
- 3.1.5 **Head:** The end of the tank that integrally includes the dome, knuckle radius and flange.
- 3.1.6 **Head flange:** The cylindrical portion of the head.
- 3.1.7 **Hydrostatic leak test:** A test when pressure is maintained over a defined period of time without leak.
- 3.1.8 **Hydrostatic pressure:** The pressure in the tank when it is completely filled with water, in psig.
- 3.1.9 **Knuckle radius:** The section of the head between the dome and the flange.
- 3.1.10 **Longitudinal:** Parallel to the centerline axis of the tank.
- 3.1.11 **Package:** The outer wrapping for the tank used for shipping purposes.

- 3.1.12 Pre-charge pressure:** The pressure of air or gas applied at the factory in psig.
- 3.1.13 Shell:** A separate cylindrical section of the tank.

3.2 SYMBOLS

- E:** Weld Efficiency for longitudinal welds (0.85).
NOTE: E = 1 if 100% of production is tested at maximum working pressure.
- P:** Manufacturer's rated maximum working pressure or 3 times pre-charge pressure at 70°F (21°C), whichever is greater.
- R:** Inside radius of head flange or shell in inches.
- S:** Allowable yield stress of steel material in psi.
- Th:** Thickness of head flange portion of a head in inches.
- Ts:** Thickness of a shell or head flange in inches.

4. MATERIALS

4.1 GENERAL

- 4.1.1** The tank manufacturer shall specify the material requirements to the material supplier in the form of chemical and mechanical requirements or by ASTM specification number.
- 4.1.2** The tank manufacturer shall verify that the materials are in compliance with their design specifications.
- 4.1.3** Materials in contact with potable water shall be in compliance with the latest applicable provisions of NSF/ANSI 61.

4.2 TYPES OF MATERIALS

4.2.1 Carbon steel

4.2.1.1 Deep drawn and stamped steel head

The steel shall meet the latest minimum requirements of ASTM A 1011/A 1011M and A 1008/A 1008M.

4.2.1.2 Rolled steel shell

Material shall be suitable for rolling and welding and meet the latest minimum requirements of ASTM Standards A 1011/A 1011M and A 1008/A 1008M.

4.2.1.3 Nonconforming steel

Steel irregularities, such as seams, cracks or laminations, shall not be used in tank construction.

4.2.2 Composite materials

Composite materials are material structures that include, but are not limited to, fiber, laminates and particulate composites.

4.2.3. Additional materials

Materials not covered under 4.2.1 and 4.2.2 are acceptable if the requirements of the applicable criteria are met.

5. DESIGN ACCEPTANCE CRITERIA

5.1 GENERAL REQUIREMENTS

A technical specification of each new tank design, including design drawings, calculations, material specifications, and required tests, shall be submitted with test sample(s) by the manufacturer to a nationally recognized testing laboratory. A tank that has received approval under these standards shall be considered to be of a new design when compared to an existing approved design when:

- a) It is manufactured in a different manufacturing facility; or
- b) It is manufactured by a different process (major process change, i.e., rolling to stamping); or
- c) It is manufactured from material of a different specification; or
- d) The tank profile has changed; or
- e) The thickness has been reduced by 10% or more; or
- f) The overall length of the tank has increased by more than 50%; or
- g) The outside diameter of the cylinder has been increased by more than 1% of the original design diameter; or
- h) The amount of fittings has increased; or
- i) The size of the openings has increased.

5.2 PROTOTYPE TESTING

5.2.1 General

The representative(s) of the prototype design shall be tested as described in subsections 5.2.2 to 5.2.5, inclusive. Prior to subjecting the tanks to prototype testing, the testing lab shall verify the product specifications.

5.2.2 Material tests

A certified physical and chemical analysis of the material shall be obtained from the material manufacturer.

5.2.3 Volume test

One tank from each design shall have the volume verified. The calculated tank volume shall be within 10% of the stated literature volume.

5.2.3.1 Each tank shall be placed on a scale to determine the tare weight of the tank. Each tank shall then be filled with fluid to the maximum volume (void of air).

5.2.4 Hydrostatic leak test

5.2.4.1 Hydrostatic leak tests shall be carried out on a minimum of three (3) representative prototype tanks of the same design.

5.2.4.2 Tests shall be carried out at room temperature. The pressure gauge shall be accurate to within 1%.

5.2.4.3 The pressure in the tank shall be increased at a rate not exceeding 20 psig per second (140 kPa/sec) until the minimum hydrostatic leak pressure is reached.

5.2.4.4 The acceptance criteria for this test shall be no external leakage during 15 minutes at the following pressure:

Metal and Composite tanks –
3 times maximum working pressure or 6 times the pre-charge pressure, whichever is greater.

5.2.5 Cyclical test

5.2.5.1 The cyclical test shall be conducted on three (3) representative prototype tanks of the same design.

5.2.5.2 Each tank shall be completely filled with water at room temperature and pressure cycled between the lowest expected pre-charge pressure and the maximum working pressure. The cycle time is to be a minimum of 5 seconds with an additional dwell time at the maximum working pressure of 5 seconds.

5.2.5.3 The acceptance criteria shall be:
10,000 cycles without leaks.

5.2.6 Test report

5.2.6.1 A test report on the prototype design shall be made. In addition, the mechanical (physical) and chemical properties of the material and the thickness of the cylindrical section of the tank shall be included in the report.

5.2.6.2 The tank manufacturer shall maintain copies of the test report(s) for the entire period that the tanks are being manufactured and five (5) years after manufacturing ceases.

6. MINIMUM CONSTRUCTION PERFORMANCE CRITERIA

6.1 DESIGN METHOD BY CALCULATION FOR STEEL TANKS

6.1.1 Head thickness: The cylindrical (head flange) thickness portion of a head shall be determined using the following equation:

$$T_h = PR/S$$

The allowable yield stress (S) is 20,000 psi or greater, if certified by the manufacturer or exempted by DOT.

6.1.2 Shell thickness: The minimum thickness of a shell shall be determined using the following equation:

$$T_s = PR/ES$$

E = Weld efficiency for longitudinal welds (0.85).

NOTE: E = 1 if 100% of production is tested at the maximum working pressure.

S = Yield strength 20,000 psi (140,000 KpA) or greater if certified by the manufacturer.

6.2 DESIGN METHOD BY HYDROSTATIC TEST

- 6.2.1** The maximum working pressure shall be determined by subjecting three (3) tanks made of the same design and from the same production run to a hydrostatic leak test. The minimum value of the leak test shall determine the maximum working pressure. The manufacturing process shall ensure repeatability of the results.
- 6.2.2** The minimum hydrostatic leak test value shall be at least 3 times the maximum working pressure or 6 times the pre-charge pressure, whichever is greater.
- 6.2.3** The hydrostatic pressure shall gradually be increased until the required test pressure is reached. It shall be held for 15 minutes. There shall be no sign of external leakage.

7. PRODUCTION TESTING

- 7.1** Prior to shipment, the manufacturer shall subject each tank to a pneumatic pressure equal to 3 times the pre-charge pressure or the maximum working pressure, whichever is greater.

8. MARKINGS

8.1 TANK MARKINGS

Each tank shall be marked, at a minimum, with the following:

- a) The manufacturer's name and address;
- b) Model identification;
- c) Serial number which will identify the date of manufacture;
- d) Maximum working pressure; AND
- e) Maximum operating temperature.

8.2 PACKAGE MARKINGS

Each package shall be marked at a minimum with the model identification of the tank.

9. INSTRUCTIONS

Each tank shall be accompanied by printed instructions for the proper installation, maintenance and safe use of the tank.

ANNEX A²

(informative)

WATER SYSTEMS COUNCIL LISTING PROGRAM

A.1 LISTINGS

A.1.1 ELIGIBILITY

In order to be eligible for listing by the Water Systems Council (WSC), Pressurized Water Storage Tanks shall be certified as meeting PST-2000 by an independent laboratory. Applicants for such listing shall identify the original equipment manufacturer of the product in their certification applications. At least one size of the same model series of these products shall be tested and certified as meeting PST-2000 in order for the entire model series to be listed.

A.1.2 SYMBOL AUTHORIZATION

Manufacturers or re-distributors of products eligible for listing may be licensed or authorized by the Water Systems Council to use its symbol of compliance with this Standard.

A.1.3 FEES FOR LISTING

Fees for listing will be set from time to time by the Water Systems Council.

A.1.4 ANNUAL RENEWAL OF PRODUCT LISTING

The Water Systems Council shall publish a list of products certified by independent testing laboratories to PST-2000 once a year. This list will be available on the WSC website. Listed manufacturers and re-distributors shall have the annual opportunity to add newly certified products to the list and incur the obligation to inform the certifying laboratory of any changes in their listed products' design or function that could necessitate a retest and re-certification.

A.2 ENFORCEMENT

WSC reserves the right to require a retest of any product on the PST-2000 list.

²The information contained in this Annex is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Annex may contain material that has not been subjected to public review of a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

Any challenge by a member or non-member to the veracity of a product's compliance with PST-2000 requirements must be submitted to WSC in writing. The letter must include the basis for the challenge as well as the name of the person and/or company submitting the information. The WSC board is responsible for determining what action, if any, will be taken.

If the retesting is required in answer to a challenge to a product listing and the returned product meets the PST-2000 standard requirements, WSC will reimburse the manufacturer for the cost of the retesting.

ANNEX B³**(informative)****PROCESS FOR PST-2000 LISTING**

WSC maintains and updates the PST-2000 published listing annually. WSC publishes the annual update of the PST-2000 List in January of each year. This list will be available on the WSC website. To be included on the updated PST-2000 list, all the below-mentioned materials must be submitted to WSC before December 15th each year, along with the payment of all fees (if applicable).

Each year in September, manufacturers with products on the current list are sent letters requesting a notarized letter signed by an officer of the company that lists all products to be listed for the current year. For products on the current list, this letter must certify that no design, materials or function changes have been made to any of these products since the current approval of the PST-2000 listing. If any changes in the listed product have been made, the revised product must be re-tested and approved separately for PST-2000 listing.

To obtain PST-2000 approval for any products made by you that have never been tested or that are not currently listed, you will need to have those products tested by an independent laboratory for PST-2000 compliance before they can be approved for listing. The independent laboratory conducting the test will also be required to ship directly to WSC the tested product along with a letter verifying that the product complies with PST-2000. Once approved and all fees have been paid, a product is immediately listed. Upon request, the Water Systems Council shall make proof of the listing available to the product manufacturer until the product appears on the published listing.

For any products that are manufactured by someone else for you and that are currently PST-2000 listed, you need to obtain a letter from the manufacturer certifying that the product model (include product number) that

³ The information contained in this Annex is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Annex may contain material that has not been subjected to public review of a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

you want PST-2000 listed is a product manufactured by that manufacturer for you and is a product currently PST-2000 listed by that manufacturer. This letter should include all product numbers for both your product and the manufacturer's product and clearly show the relationship between each.



ANSI/WSC PST 2000 - 2005 –
Pressurized Water Storage Tank Standard



WATER SYSTEMS COUNCIL
NATIONAL PROGRAMS OFFICE
(202) 625-4387
www.watersystemscouncil.org

September 2005